दुरध्वनी : 25331211 25331590



ठाणे महानगरपालिका,ठाणे.

महानरगपालिका भवन,सरसेनानी जनरल अरुणकुमार वैद्य मार्ग, चंदनवाडी पांचपाखाडी ,ठाणे ४०० ६०२. THE MUNICIPAL CORPORATION OF THE CITY OF THANE

Ref/T.M.C./CFO/M - 966

Date - 11/03) 2024

FIRE SAFETY CERTIFICATE

Certified that the <u>SARASWATI VIDYALAYA</u> (name of the building or Premises) at <u>Kavesar, Near Swastik Residency, G.B. Road, Thane. (w) 400615.</u> (address) Comprised of <u>Ground +</u> 4th Floor owned / occupied by SARASWATI VIDYALAYA, Kavesar, Near Swastik Residency, G.B. <u>Road, Thane. (w)</u> (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 13/02/2024 (date of inspection) in the presence of AAYUSH Fire And Safety Services (name and addresses of the Manager/ Secretary or his representative) and that the building / premises is fit for occupancy up to classes <u>I to X (X /XII)</u> With effect from <u>11.03.2024</u> for a period of <u>One year</u> in accordance with rule and subject to compliance of specific conditions as appended:-

1. Hydrant Main Fire Pump	- Yes	8. 2 Way Tank Inlet	- Yes
2. MCC Panel	- Yes	9. Fire Bucket	- Yes
3. Canvas Hose Pipe	- Yes	10. Single Door Hose Box	- Yes
4. Hose Real	- Yes	11. ABC Fire Extinguisher 4Kg Cap.	- Yes
5. Fire Alarm Panel with PA	- Yes	12. Booster Pump 900 LPM	- Yes
6. MCP Cum Hooter	- Yes	13. Foot Valve 150mm Dia	- Yes
7. 2 Way Fire Inlet	- Yes	14. Pressure Switch	- Yes
Issued on 11 / 03 / 2024 (date of issue) at Thane (place) by Signature with seal:			



Name

: Mr. Girish. M. Zalke

Designation

: Chief Fire Officer, Thane

Name & Address of Department/ Office : Chief Fire Officer, Thane

Chief Fire Officer, Thane Municipal Fire Brigade, Thane.

То

SARASWATI VIDYALAYA Kavesar, Near Swastik Residency, G.B. Road, Thane. (w) 400615. (Name & Address of the Institution)

ENDORSEMENT

The no objection certificate issued by Fire Service stand cancelled and annulled due to <u>negligence of</u> any fire safety norms laid by state government.

This Fire Safety Certificate Subject to Submission of Form B For Every Six Month as per Maharashtra Fire Prevention & Life Safety Act 2006.

(Name and designation of the authorized signatory)

PRINCIPAL SARASWATI VIDYALAYA KAVESAR, G.B. ROAD, THANE (W)