



ठाणे महानगरपालिका  
THE MUNICIPAL CORPORATION OF THE CITY OF THANE  
प्रदूषण नियंत्रण कक्ष  
POLLUTION CONTROL CELL



E-mail : pcctmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,  
चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6<sup>th</sup> November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas ,Naupada Thane. Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 3560  
Sample No. : P1584

Date : 6 March 2024

**Water Analysis Report**

TMC/PCC/20/RO

Name Of the Organisation : M/S Saraswati Vidyalaya

Address : Kavesar, Near Swastik Residency, Ghodbunder road, Thane

E\_mail ID : saraswatividyalaya@gmail.com

Date of receiving Sample : 05 March 2024

Sample Collected by : TMC Representative (Vivek Darekar)

Type of Water Sample : Storage Drinking (2nd Sample)

Parameters	Results	Limits as per IS 10500
pH	7.70	6.5 - 8.5
Free Residual Chlorine	Nil	1 ppm
Turbidity	3.0	5 NTU
Chloride	30.0	250 mg/L
Total Hardness	75.0	300 mg/L
Total Coilform Bacteria ( MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH .

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

6-Mar-24

Prabhakar Sonawale

Thane Municipal Corporation, Thane

Authorised by

6-Mar-24

Omsatyashiv Paralkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking (2nd Sample) Water sample received to our Vakratunda Laboratory on 5/3/2024. This further acknowledges that you have paid the charges Rs. 6380/- vide Receipt No.TMC/LOS/PLC/000215/22-23 dated 09.11.2022

This Report has been Signature Digitally.

PRINCIPAL  
SARASWATI VIDYALAYA  
KAVESAR, G.B. ROAD, THANE (W)